



ANALYTICAL REPORT

Montana Environmental Laboratory LLC

1170 N. Meridian Rd., P.O. Box 8900, Kalispell, MT 59904-1900

Phone: 406-755-2131 Fax: 406-257-5359 www.melab.us

Marc Liechti
Wetington Water District
3300 Hwy 2 West
Kalispell, MT 59901

PWS ID: 04083
Project: IOCs

Client Sample ID: WL002, EP502

Lab ID: 2512749-01

Matrix: DRINKING WATER

Collected: 11/24/2025 12:00

Received: 11/24/2025 13:10

IOCs phase II & V

	<u>Result</u>	<u>Units</u>	<u>RL</u>	<u>MCL</u>	<u>Method</u>	<u>Prepared</u>	<u>Analyzed</u>	<u>Analyst</u>
Antimony	ND	mg/L	0.001	0.006	E200.8		11/26/2025 15:08	BLW
Arsenic	0.006	mg/L	0.001	0.010	E200.8		11/26/2025 15:08	BLW
Barium	ND	mg/L	0.01	2	E200.8		11/26/2025 15:08	BLW
Beryllium	ND	mg/L	0.001	0.004	E200.8		11/26/2025 15:08	BLW
Cadmium	ND	mg/L	0.001	0.005	E200.8		11/26/2025 15:08	BLW
Chromium	ND	mg/L	0.001	0.1	E200.8		11/26/2025 15:08	BLW
Fluoride	0.93	mg/L	0.01	4	E300.0		11/25/2025 16:30	BLW
Mercury	ND	mg/L	0.0001	0.002	E200.8		11/26/2025 15:08	BLW
Nickel	0.008	mg/L	0.001	1	E200.8		11/26/2025 15:08	BLW
Nitrate	0.06	mg/L	0.01	10	E353.2		11/25/2025 16:30	NB
Nitrate + Nitrite, Total	0.06	mg/L	0.01	10	E353.2		11/25/2025 16:30	BLW
Nitrite	ND	mg/L	0.01	1	E353.2		11/25/2025 16:30	BLW
Selenium	ND	mg/L	0.001	0.05	E200.8		11/26/2025 15:08	BLW
Sulfate	36.8	mg/L	0.1	500	E300.0		11/25/2025 16:30	BLW
Thallium	ND	mg/L	0.0005	0.002	E200.8		11/26/2025 15:08	BLW



ANALYTICAL REPORT

Montana Environmental Laboratory LLC

1170 N. Meridian Rd., P.O. Box 8900, Kalispell, MT 59904-1900

Phone: 406-755-2131 Fax: 406-257-5359 www.melab.us

Marc Liechti
Wetington Water District
3300 Hwy 2 West
Kalispell, MT 59901

PWS ID: 04083
Project: IOCs

Client Sample ID: WL003, EP503

Lab ID: 2512749-02

Matrix: DRINKING WATER

Collected: 11/24/2025 12:15

Received: 11/24/2025 13:10

IOCs phase II & V

	<u>Result</u>	<u>Units</u>	<u>RL</u>	<u>MCL</u>	<u>Method</u>	<u>Prepared</u>	<u>Analyzed</u>	<u>Analyst</u>
Antimony	ND	mg/L	0.001	0.006	E200.8		11/26/2025 15:08	BLW
Arsenic	0.003	mg/L	0.001	0.010	E200.8		11/26/2025 15:08	BLW
Barium	0.03	mg/L	0.01	2	E200.8		11/26/2025 15:08	BLW
Beryllium	ND	mg/L	0.001	0.004	E200.8		11/26/2025 15:08	BLW
Cadmium	0.001	mg/L	0.001	0.005	E200.8		11/26/2025 15:08	BLW
Chromium	ND	mg/L	0.001	0.1	E200.8		11/26/2025 15:08	BLW
Fluoride	1.37	mg/L	0.01	4	E300.0		11/25/2025 16:30	BLW
Mercury	ND	mg/L	0.0001	0.002	E200.8		11/26/2025 15:08	BLW
Nickel	0.009	mg/L	0.001	1	E200.8		11/26/2025 15:08	BLW
Nitrate	ND	mg/L	0.01	10	E353.2		11/25/2025 16:30	NB
Nitrate + Nitrite, Total	ND	mg/L	0.01	10	E353.2		11/25/2025 16:30	BLW
Nitrite	ND	mg/L	0.01	1	E353.2		11/25/2025 16:30	BLW
Selenium	ND	mg/L	0.001	0.05	E200.8		11/26/2025 15:08	BLW
Sulfate	138	mg/L	0.1	500	E300.0		12/02/2025 11:36	BLW
Thallium	ND	mg/L	0.0005	0.002	E200.8		11/26/2025 15:08	BLW



ANALYTICAL REPORT

Montana Environmental Laboratory LLC

1170 N. Meridian Rd., P.O. Box 8900, Kalispell, MT 59904-1900

Phone: 406-755-2131 Fax: 406-257-5359 www.melab.us

Marc Liechti
Wetington Water District
3300 Hwy 2 West
Kalispell, MT 59901

PWS ID: 04083
Project: IOCs

Client Sample ID: WL004, EP504

Lab ID: 2512749-03

Matrix: DRINKING WATER

Collected: 11/24/2025 12:30

Received: 11/24/2025 13:10

IOCs phase II & V

	<u>Result</u>	<u>Units</u>	<u>RL</u>	<u>MCL</u>	<u>Method</u>	<u>Prepared</u>	<u>Analyzed</u>	<u>Analyst</u>
Antimony	ND	mg/L	0.001	0.006	E200.8		11/26/2025 15:08	BLW
Arsenic	0.005	mg/L	0.001	0.010	E200.8		11/26/2025 15:08	BLW
Barium	0.03	mg/L	0.01	2	E200.8		11/26/2025 15:08	BLW
Beryllium	ND	mg/L	0.001	0.004	E200.8		11/26/2025 15:08	BLW
Cadmium	0.001	mg/L	0.001	0.005	E200.8		11/26/2025 15:08	BLW
Chromium	ND	mg/L	0.001	0.1	E200.8		11/26/2025 15:08	BLW
Fluoride	1.37	mg/L	0.01	4	E300.0		11/25/2025 16:30	BLW
Mercury	ND	mg/L	0.0001	0.002	E200.8		11/26/2025 15:08	BLW
Nickel	0.009	mg/L	0.001	1	E200.8		11/26/2025 15:08	BLW
Nitrate	ND	mg/L	0.01	10	E353.2		11/25/2025 16:30	NB
Nitrate + Nitrite, Total	ND	mg/L	0.01	10	E353.2		11/25/2025 16:30	BLW
Nitrite	ND	mg/L	0.01	1	E353.2		11/25/2025 16:30	BLW
Selenium	ND	mg/L	0.001	0.05	E200.8		11/26/2025 15:08	BLW
Sulfate	138	mg/L	0.1	500	E300.0		12/02/2025 11:36	BLW
Thallium	ND	mg/L	0.0005	0.002	E200.8		11/26/2025 15:08	BLW